


LIN'S GRAND BUFFET


HWY 287 AT PEARL RD.

CASA GRANDE, ARIZONA

LOGOS BUILDERS SOUTHWEST



winton architects, inc.
 Phoenix, Az. 85014
 1435 E. Rancho Drive
 (602) 230-9778
 wintonarch@gmail.com



REMODEL FOR RESTAURANT
 1564 E. FLORENCE BLVD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn LB
 approved RBW
 date 7/10/20

revisions


COVER
 47

GENERAL CONSTRUCTION DOCUMENT NOTES


- The contractor or sub contractor will inspect the premises prior to his commencing work to check existing working conditions. Should contractor or subcontractor find conditions which he believes would impede his work, then such conditions must be reported immediately to the architect. Failure to so advise will constitute notice that the contractor is fully satisfied and that he intends to perform his obligations with no allowance either in time or money for any impediments to his work.
- Contractor shall verify all dimensions and conditions in field. If dimensional error occurs or conditions not covered on the drawings is encountered, contractor shall notify the architect before commencing that portion of the work.
- Details, notes and finishes shall be applicable to all typical conditions whether or not referenced at all places.
- The contractor shall take all necessary precautionary measures to protect the public and adjacent properties from damages throughout construction. He shall meet the latest requirements of the United States Department of Labor Occupational Safety and Health Standards and comply with: the Manual of Accident Prevention in Construction; all applicable safety and sanitary laws, regulations and ordinances; and any safety rules or procedures established by the Owner for the project.
- The contractor is exclusively responsible for loss or expense resulting from injury on the project site. He assumes all risks in the performance of the work and is responsible for supervision, materials, equipment and labor required to implement the plans and specifications.
- The contractor is solely responsible for supervision, safety, administration and all phases of its contract. He is also responsible for scheduling, coordinating, management and administration or sub consultants.
- The contractor shall verify any new mechanical unit loads at roof and/or suspended below and their locations. Notify the architect of any changes in size or location.
- The contractor shall verify the location of existing utilities and protect the same.
- All work shall comply with all applicable codes and ordinances.
- All manufactured articles, materials and equipment shall be applied, installed, connected, erected, used, cleaned and conditioned in accordance with the manufacturer's written specification or instruction unless hereinafter specified to the contrary.
- Dimensions take precedence over scale or construction documents.
- All work shall be executed in a neat and workmanlike manner, acceptable to Owner.
- When work not specifically called out is required to complete the project, it shall be provided and be of the best materials and workmanship.
- Contractor shall guarantee all workmanship and materials for a period of one year from the date of substantial completion (in writing).
- Unless otherwise specifically noted, the contractor shall provide and pay for all labor, materials, equipment, tools, construction equipment and machinery, transportation, and other facilities and services necessary for proper execution and completion of the work.
- The contractor shall pay for all fees, permits, etc. necessary for proper completion of work. (U.N.O.)
- The contractor warrants to the owner and the architect that all materials and equipment furnished under this contract will be new unless otherwise specified, and that all work will be good quality, free from faults and defects and in conformance with the construction documents. All work not conforming to these standards may be considered defective. It is understood that no inferior or non-conforming work or materials will be accepted whether discovered at the time they are incorporated in the work or at any time before or after final acceptance. If required by the architect, the contractor shall furnish satisfactory evidence as to the kind and quality of materials and equipment.
- The warranties and guarantees provided in the construction documents shall be in addition to and not in limitation of any other warranty or guaranty or remedy required by law or by the construction documents.
- The contractor is to provide warning signs and lights, barricades, railings and other safeguards.
- The design professional's inspection for compliance with the plans and specifications shall NOT be deemed supervision or control of construction means or methods employed by the contractor or any subcontractor.

SCHEDULE OF SHEETS

Cover	General Construction Notes, Schedule of Sheets
SP-1	Site Plan, Project Data
D-1	Demolition Plan
A-1	Foundation Plan
A-2	Floor Plan
A-2.1	Overall Floor Plan, Keynotes
A-3	Exterior Elevations
A-4	Building Sections
A-4.1	Building Sections
S-1	General Structural Notes
S-2	Footing Details
S-3	Foundation Plan
M-1	Mechanical Floor Plan
M-2	Mechanical Notes, Schedules
P-1	Plumbing Floor Plan-Waste, Vent piping
P-2	Plumbing Floor Plan- Water Piping
P-3	Plumbing Floor Plan- Gas Piping
P-4	Waste and Vent Diagram, Notes
E-0.0	Electrical Specifications
E-0.1	Electrical Equipment Requirements
E-1.0	Electrical Power Plan
E-2.0	Electrical Lighting Plan
E-3.0	Electrical HVAC Plan
E-4.0	Panel Board Schedule
E-5.0	One Line Diagram
FS1.0	Equipment Floor Plan
FS1.1	Equipment Schedule
FS1.2	Equipment Schedule
FS2.0	Plumbing Rough In Plan
FS2.1	Plumbing Rough In Plan
FS2.2	Plumbing Rough In Plan
FS2.3	Plumbing Rough In Plan
FS3.0	Electrical Rough In Plan
FS4.0	Mechanical Rough In Plan
FS4.1	Mechanical Specifications
FS4.2	Mechanical Specifications
FS4.3	Mechanical Specifications
FS4.4	Mechanical Specifications
FS4.5	Mechanical Specifications
FS4.6	Mechanical Specifications
FS4.7	Mechanical Specifications
FS4.8	Mechanical Specifications
FS4.9	Mechanical Specifications
FS4.10	Mechanical Specifications
FS4.11	Mechanical Specifications
FS5.0	Special Conditions Plan
FS6.0	Walk In Specifications



winton architects, inc.
 Phoenix, Az. 85014
 1435 E. Rancho Drive
 (602) 230-9778
 wintonarch@gmail.com



REMODEL FOR RESTAURANT
 HWY 287 AT PEARL RD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn LB
 approved RBW
 date 7/10/20

revisions
 OWNER 10/23/20
 OWNER 1/18/21

SP-1

PROJECT DATA




ADDRESS: 1564 E. Florence Blvd
 ZONING: PAD
 CONSTRUCTION TYPE: VB, AFES
 ALLOWABLE AREA: 24,000 SF
 OCCUPANCY: A-3
 BUILDING HEIGHT: 26'-4"
 BUILDING AREA: Existing= 5132 SF
 New Addition= 329 SF
 Total= 5,461 SF
 PARKING REQUIRED: 90% x 5461=4915/100= 50 Spaces
 PARKING PROVIDED: 62 Spaces
 ACCESSIBLE SPACES REQUIRED: 3 Spaces
 ACCESSIBLE SPACES PROVIDED: 3 Spaces
 SEATING CAPACITY: TBD
 LEGAL DESCRIPTION: PAD 'C' - Casa Grande Market

APPLICABLE CODES

- 2017 National Electrical Building Code (NEC)
- 2018 International Building Code (IBC)
- 2018 International Energy Conservation Code (IECC)
- 2018 International Existing Building Code (IEBC)
- 2018 International Fire Code (IFC)
- 2018 International Fuel Gas Code (IFGC)
- 2018 International Mechanical Code (IMC)
- 2018 International Plumbing Code (IPC)
- City of Casa Grande Building and Technical Administration Code, 2019 Edition

SCOPE OF WORK

This is an existing Restaurant that is being converted to a Chinese Restaurant. The inside was based on drawings could be created for a new permit. Work includes Structural, Architectural, Electrical, Mechanical/Plumbing and Kitchen Design.



20118

PAD D
3,500 SF.

HVAC ELECT. REQUIREMENTS

- ELECTRICAL CONTRACTOR SHALL PROVIDE CORRECT SIZE/TYPE/VOLTAGE/QUANTITY OF DUAL-ELEMENT, TIME-DELAY FUSE(S) SIZED PER HVAC EQUIPMENT MANUFACTURER UNLESS OTHERWISE SPECIFIED BY UNIT NAMEPLATE/MANUFACTURER DATA.
- ALL CONDUCTORS SHALL BE IN ACCORDANCE WITH THE ELECTRICAL SYSTEM SPEC'S (3.2). ALL TAP CONDUCTORS SHALL MEET THE REQUIREMENTS OF NEC ARTICLE 240.21(B)(2). MAXIMUM TAP CONDUCTOR LENGTH SHALL BE 25'-0" PER NEC ARTICLE 240.21(B)(2). "FEEDER TAPS" AND "TRANSFORMER SECONDARY CONDUCTORS" AND SHALL NOT BE SMALLER THAN 1/3 THE CAPACITY OF FEEDER CONDUCTORS.
- PROVIDE MAGNETIC MOTOR STARTER WITH THERMAL OVERLOAD PROTECTION, (2) AUXILIARY CONTACT SWITCHES, INTERNAL LINE VOLTAGE TO 24 VOLT TRANSFORMER (250VA. MIN) WITH PROPER PRIMARY/SECONDARY PROTECTION, AMBIENT COMPENSATED, RED RUNNING LIGHT, HAND-OFF-AUTO, ACROSS THE LINE STARTERS TO 25HP. WILL BE PROVIDED WITH EACH MOTOR ON THE DRAWINGS (ONE HORSEPOWER TO 25 H.P.).

EQUIPMENT INDICATED HERE SHALL BE LISTED TO THE APPROPRIATE U.L. LISTING FOR THE USE AND BEAR A NAMEPLATE WITH THIS INFORMATION. WHEN REQUIRED, ANY NON-COMPLIANT EQUIPMENT MUST BE MADE COMPLIANT AT THE OWNERS EXPENSE AND IS NOT A PART OF THIS WORK EFFORT.

UNIT	VOLTS/Φ	FULL LOAD AMPS	DISCONNECTING MEANS	CONDUCTORS/ CONDUIT
1 KEF 1	208/3	FLA HP 8.3 2	HEAVY DUTY 30AMP 250V 3P/3F NEMA 3R DISCONNECT SWITCH	(3)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 KEF 2	208/3	FLA HP 9.5 3	HEAVY DUTY 30AMP 250V 3P/3F NEMA 3R DISCONNECT SWITCH	(3)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 KEF 3	208/3	FLA HP 2.8 3/4	HEAVY DUTY 30AMP 250V 3P/3F NEMA 3R DISCONNECT SWITCH	(3)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 KEF 4	208/3	FLA HP 9.5 3	HEAVY DUTY 30AMP 250V 3P/3F NEMA 3R DISCONNECT SWITCH	(3)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 KEF 5	120/1	FLA HP 6.3 1/2	120V 20A MOTOR RATED TOGGLE SWITCH	(2)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 MAU 1	208/3	MCA MOOP 19.8 35	HEAVY DUTY 60AMP 250V 3P/3F NEMA 3R DISCONNECT SWITCH	(3)#8's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 MAU 2	208/3	MCA MOOP 8.3 15	HEAVY DUTY 30AMP 250V 3P/3F NEMA 3R DISCONNECT SWITCH	(3)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
1 WH 1	120/1	FLA HP 16.0 -	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
1 CP 1	120/1	FLA HP 4.4 1/35	120V 20A MOTOR RATED TOGGLE SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.

ELECT. EQUIP. REQUIREMENTS


- ELECTRICAL CONTRACTOR SHALL PROVIDE CORRECT SIZE/TYPE/VOLTAGE/QUANTITY OF DUAL-ELEMENT, TIME-DELAY FUSE(S) SIZED PER EQUIPMENT MANUF. UNLESS OTHERWISE SPECIFIED BY UNIT NAMEPLATE/MANUFACTURER DATA.
- ALL FEEDERS SHALL BE IN ACCORDANCE WITH THE ELECTRICAL SYSTEM SPEC'S (3.2).
- COORDINATE EXACT LOCATIONS OF ALL EQUIPMENT PRIOR TO ROUGH-IN.

LABEL	VOLTS/Φ	FLA	BRANCH CIRCUIT	CONNECTION TYPE	CONDUCTORS/ CONDUIT
E1 AMERKÖOLER FREEZER	120/1	6	PANEL CIRCUIT KA-1 1	HEAVY DUTY 30AMP 250V 2P/1F NEMA 3R DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E2 AMERKÖOLER EVAPORATOR	120/1	5	PANEL CIRCUIT KA-1 3	HEAVY DUTY 30AMP 250V 2P/1F NEMA 3R DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E3 AMERKÖOLER REMOTE CONDENSER	208/1	20	PANEL CIRCUIT KA-1 (22-24)	HEAVY DUTY 30AMP 250V 2P/1F NEMA 3R DISC. SWITCH	(2)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
E4 CIA DISMACHINES	208/3	55	PANEL CIRCUIT KA-1 (15-17-18)	HEAVY DUTY 100AMP 250V 2P/3F NEMA 1 DISC. SWITCH	(3)#4's Cu., (1)#10 Cu. E.G. - 1" C.
E5 LANCER SODA DISPENSER	120/1	4	PANEL CIRCUIT KA-1 11	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E6 CURTIS COFFEE BREWER	120/1	12.7	PANEL CIRCUIT KA-1 13	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E7 HOSHIZAKI ICE MACHINE	208/3	12.9	PANEL CIRCUIT KA-1 (8-10-12)	HEAVY DUTY 30AMP 250V 3P/3F NEMA 1 DISC. SWITCH	(3)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E8 HOSHIZAKI REMOTE CONDENSER	120/1	3	PANEL CIRCUIT KA-1 14	HEAVY DUTY 30AMP 250V 2P/1F NEMA 3R DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E9 MOFFAT CONNECTION OVEN	120/1	3	PANEL CIRCUIT KA-1 2	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E10 TURBO AIR REFRIGERATOR #1	120/1	2.8	PANEL CIRCUIT KA-1 18	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E11 PANASONIC RICE COOKER	208/1	10.8	PANEL CIRCUIT KA-1 (20-22)	HEAVY DUTY 30AMP 250V 2P/2F NEMA 3R DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E12 TURBO AIR REFRIGERATOR #2	120/1	2.8	PANEL CIRCUIT KA-1 24	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E13 TURBO AIR REFRIGERATOR #3	120/1	2.8	PANEL CIRCUIT KA-1 23	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E14 TURBO AIR REFRIG. STAND	120/1	3.3	PANEL CIRCUIT KA-1 25	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E15 HATCO COLD FOOD WELL	120/1	8	PANEL CIRCUIT KA-1 26	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E16 HATCO HOT FOOD WELL #1	208/1	24	PANEL CIRCUIT KA-1 (28-30)	HEAVY DUTY 30AMP 250V 2P/2F NEMA 1 DISC. SWITCH	(2)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
E17 HATCO HOT FOOD WELL #2	208/1	16	PANEL CIRCUIT KA-1 (34-36)	HEAVY DUTY 30AMP 250V 2P/2F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E18 a,b HATCO HOT FOOD WELLS #3,4	208/1	24	PANEL CIRCUIT KA-1 (33-35) (39-41)	HEAVY DUTY 30AMP 250V 2P/2F NEMA 1 DISC. SWITCH	(2)#10's Cu., (1)#10 Cu. E.G. - 3/4" C.
E19 PIPER PRODUCTS REFRIG. MERCHANDISER	208/1	7	PANEL CIRCUIT KA-2 (1-3)	HEAVY DUTY 30AMP 250V 2P/2F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E20 TAYLOR COMPANY SOFT SERVE EQUIP.	208/3	25	PANEL CIRCUIT KA-2 (5-7-9)	HEAVY DUTY 60AMP 250V 2P/2F NEMA 1 DISC. SWITCH	(3)#8's Cu., (1)#10 Cu. E.G. - 3/4" C.
E21 LANCER SYRUP TANK RACK	120/1	12	PANEL CIRCUIT KA-2 11	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E22 TURBO AIR REFRIGERATOR #4	120/1	2.8	PANEL CIRCUIT KA-2 2	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E23 a-d HATCO COLD SLAB #1-4	120/1	8	PANEL CIRCUIT KA-2 4,6,8,10	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E24 a,b HATCO COLD SLAB #5,6	120/1	12	PANEL CIRCUIT KA-2 12,14	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E25 TURBO AIR PREP REFRIGERATOR	120/1	4.4	PANEL CIRCUIT KA-2 13	120V, 20A NEMA 5-20R W/ GFCI CIRCUIT BREAKER	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E26 CAPTIVE-AIRE HOOD-LARGE WOK	120/1	8	PANEL CIRCUIT KA-2 15	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E27 CAPTIVE-AIRE HOOD-SMALL WOK	120/1	8	PANEL CIRCUIT KA-2 19	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E28 CAPTIVE-AIRE HOOD-ISLAND	120/1	8	PANEL CIRCUIT KA-2 23	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E29 CAPTIVE-AIRE HOOD-MONGOLIAN	120/1	8	PANEL CIRCUIT KA-2 27	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.
E30 CAPTIVE-AIRE HOOD-OSH	120/1	8	PANEL CIRCUIT KA-2 31	HEAVY DUTY 30AMP 250V 2P/1F NEMA 1 DISC. SWITCH	(2)#12's Cu., (1)#12 Cu. E.G. - 3/4" C.

NOTE:
PROVIDE GFCI CIRCUIT BREAKER AS LISTED IN LIEU OF GFCI RECEPTACLE TO ALLOW READILY ACCESSIBILITY PER NEC 210.8. CONTRACTOR MAY INSTALL A GFCI-TYPE RECEPTACLE IN LIEU OF GFCI CIRCUIT BREAKER, IF THE DEVICE IS READILY ACCESSIBLE WITH THE EQUIPMENT IN PLACE.

KEYED NOTES

- 1 PROVIDE INTERLOCK REQUIREMENTS OF HVAC EQUIPMENT AND INTERFACE WITH FIRE PROTECTION SYSTEM. VERIFY EXACT REQUIREMENTS WITH MECHANICAL PLANS.



WAWinton architects, inc.
1110 E. Missouri Ave., Suite 800, Phoenix, Arizona 85014
(602) 230-9778 FAX (602) 265-9739

REMODEL FOR RESTAURANT
1564 E. FLORENCE BLVD.
CASA GRANDE, ARIZONA
LOGOS BUILDERS SOUTHWEST

job no. 20118
drawn CRC
approved AG
date 4/30/2021

revisions

E-0.1

DESIGN CODES
IECC, 2018 NEC, 2017

ELECTRICAL CONTRACTOR SHALL NOTIFY DESIGNER/ENGINEER PRIOR TO ANY DEVIATION FROM THIS SET OF ELECTRICAL DESIGN PLANS. ANY CHANGES TO THE DESIGN, IF APPROVED BY ENGINEER, WILL REQUIRE REVISIONS TO PLANS AND POSSIBLE ADDITIONAL SERVICE FEE.

Project Contact/Designer: **Chad Curry**
Project #21112


HAWKINS DESIGN GROUP INC.
ELECTRICAL CONSULTING ENGINEERS
190 WEST HARVEL ROAD
CUMBERLAND, ARIZONA 85233
PH 480.813.9000 FAX 480.813.9001
EMAIL: email@hawkinsdesign.com

All concepts, designs and data indicated on these drawings are the sole property of the Hawkins Design Group Inc. and shall not be used for any other purpose other than originally intended without written permission of the engineer.

IF DRAWING IS NOT PLOTTED AT 24 X 36 THEY ARE NOT FULL SIZE



W winton architects, inc.
 1110 E. Missouri Ave., Suite 800, Phoenix, Arizona 85014
 (602) 230-9778



REMODEL FOR RESTAURANT
 1564 E. FLORENCE BLVD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn CRC
 approved AG
 date 4/30/2021

revisions

E-1.0

GENERAL NOTES - POWER

- REFER TO ELECTRICAL SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND COMPLETE CONTRACTUAL OBLIGATIONS.
- THE ELECTRICAL CONTRACTOR SHALL (PRIOR TO HIS BID) VISIT THE SITE AND FIELD VERIFY ALL EXISTING CONDITIONS AND TAKE ALL CONSIDERATIONS INTO ACCOUNT AT THE TIME OF BID. NO ADDITIONAL CONSIDERATIONS WILL BE GRANTED THE CONTRACTOR AFTER THE BID IS ACCEPTED.
- ALL ELECTRICAL METALLIC TUBING (EMT), RIGID NON-METALLIC CONDUIT, FLEXIBLE METALLIC CONDUIT, FLEXIBLE NON-METALLIC CONDUITS, "SEALTIGHT" TYPE CONDUITS AND ALL OTHER CONDUITS THAT DO NOT CONTAIN A CODE SIZED GROUND WIRE SHALL HAVE A CODE SIZED BOND WIRE PER NEC TABLE 250.122 INSTALLED WITH THE CIRCUIT CONDUCTORS.
- RECEPTACLES LOCATED WITHIN 6'-0" OF SINKS OR WATER SHALL BE CONNECTED EITHER TO A GROUND FAULT CIRCUIT INTERRUPTER TYPE CIRCUIT BREAKER OR TO A GROUND FAULT CIRCUIT INTERRUPTER TYPE RECEPT.
- PRIOR TO ROUGH-IN, THE ELECTRICAL CONTRACTOR SHALL COORDINATE THE EXACT LOCATION OF ALL WIRING DEVICES TO INCLUDE MOUNTING HEIGHTS AND LOCATIONS. ALL CONFLICTS SHALL BE REPORTED TO THE ENGINEER/ARCHITECT.

KITCHEN NOTES
 (NOT ALL MAY APPLY)

- FINAL CONNECTION TO ALL KITCHEN EQUIPMENT SHALL BE MADE WITH "SEAL-TITE" FLEXIBLE CONDUIT.
- THE ELECTRICAL CONTRACTOR SHALL MAKE FINAL ELECTRICAL CONNECTIONS TO ALL KITCHEN FOOD SERVICE AND RELATED EQUIPMENT.
- (E) INDICATES FOOD SERVICE EQUIPMENT IDENTIFICATION NUMBER. SEE FOOD SERVICE DRAWING FOR ADDITIONAL INFORMATION.
- THE ELECTRICAL CONTRACTOR SHALL VERIFY ROUGH-IN REQUIREMENTS, LOCATIONS, MOUNTING HEIGHTS, VOLTAGE, PHASE, AMPS, HP, KW, ETC. FOR ALL FOOD SERVICE EQUIPMENT PRIOR TO ROUGH-IN. SEE KITCHEN AND HOOD DRAWINGS FOR ADDITIONAL INFORMATION AND REQUIREMENTS.
- PROVIDE SEAL-OFF'S FOR ALL CONDUITS ENTERING OR LEAVING WALK-IN BOXES.
- KITCHEN HOOD EXHAUST FAN AND MAKE-UP AIR UNIT SHALL BE INTERLOCKED AND THE CONTROL CIRCUIT SHALL BE ROUTED THRU DRY CONTACTS PROVIDED IN THE FIRE PROTECTION SYSTEM. THE MAKE-UP AIR UNIT FAN(S) SHALL SHUT DOWN UPON ACTIVATION OF THE FIRE PROTECTION SYSTEM. (PROVIDE RELAY IF REQUIRED).
- ALL CIRCUIT BREAKERS PROVIDED WITH SHUNT TRIPPING DEVICES SHALL HAVE THE CONTROL CIRCUIT ROUTED THRU DRY CONTACTS PROVIDED IN THE FIRE PROTECTION SYSTEM. UPON ACTIVATION OF FIRE PROTECTION SYSTEM THOSE CIRCUIT BREAKERS SHALL BE AUTOMATICALLY TRIPPED.
- THE ELECTRICAL CONTRACTOR SHALL VERIFY THE ROUGH-IN REQUIREMENTS, LOCATIONS, ORIENTATION, VOLTAGE, PHASE, HP, KW, ETC. FOR ALL HVAC AND PLUMBING EQUIPMENT PRIOR TO ROUGH-IN.
- ALL CIRCUITS SHALL HAVE AN INSULATED GROUND WIRE (BOND) SIZED PER N.E.C. #250.95 #12 MINIMUM GROUND. WIRE NOT SHOWN ON DRAWINGS.
- THE ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL DISCONNECT SWITCHES, CONDUIT, WIRE AND INSTALL UNDER SUPERVISION OF KITCHEN EQUIPMENT SUPPLIER.
- THE ELECTRICAL CONTRACTOR SHALL VERIFY THE PLUG CONFIGURATIONS FOR APPLICABLE KITCHEN EQUIPMENT WITH SUPPLIER PRIOR TO ROUGH-IN.
- ALL DEVICES, CONDUIT, ETC. SHALL BE INSTALLED PER LOCAL HEALTH CODES AND ORDINANCES.
- DEVICES COVERPLATES SHALL BE STAINLESS STEEL AND JUNCTION BOXES SHALL BE TYPE "FS".

SYMBOL LEGEND

- X - EXISTING TO BE DEMOLISHED
 - EM - EMERGENCY LIGHT
 - E - EXISTING TO REMAIN UNCHANGED
 - R - RELOCATED TO LOCATION AS SHOWN, EXTEND EXISTING CONDUIT AND CONDUCTORS AS SHOWN.
 - N - NEW ELECTRICAL DEVICE (UNMARKED DEVICES ARE TO BE CONSIDERED NEW)
- NOTE: NOT ALL SYMBOLS ARE USED.

KEYED NOTES

- LOCATION OF EXISTING SES.
- LOCATION OF EXISTING PANELBOARDS "MP", "A", "M", "KB", "KA-1", "KA-2".
- PROVIDE HVAC MAINTENANCE W.P. GFCI PER NEC SECTION 210.63 WITH WHILE-IN-USE COVER AND OUTLET BOX HOOD SHALL BE LISTED AND IDENTIFIED AS "EXTRA-DUTY" PER NEC 406.9(B)(1). TIE INTO CIRCUIT "KA-1"-9.
- ALL EXISTING POWER IN THIS AREA TO REMAIN UNCHANGED.
- EXISTING LIGHTING DIMMER CONTROL PANEL "D".
- WALK-IN COOLER CU UNIT ON EXTERIOR SLAB. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER PRIOR TO INSTALL.
- PROVIDE WEATHER PROOF JUNCTION BOX WITH 120V 20A CIRCUIT FOR WALK-IN COOLER/FREEZER ACCESSORIES. VERIFY EXACT REQUIREMENTS WITH EQUIPMENT MANUFACTURER PRIOR TO INSTALL.
- STUB OUT FOR UNDERGROUND CONDUIT. EMPTY CONDUIT FOR HEAT LAMPS FOR BUFFET AREA SELF-SERVICE. COORDINATE EXACT LOCATIONS AND REQUIREMENTS WITH OWNER PRIOR TO ROUGH-IN. FROM PANELBOARD "KB" TO LOCATION SHOWN.
- RELOCATED PLYWOOD TELEPHONE MOUNTING BOARD "TMB".
- RELOCATED FIRE ALARM CONTROL PANEL "FACP".

VERIFY ALL KITCHEN EQUIPMENT LOCATIONS WITH ARCHITECT PRIOR TO ROUGH-IN.

CONTRACTOR SHALL PROVIDE FINAL CONNECTION TO ALL EQUIPMENT. VERIFY ALL KITCHEN EQUIPMENT REQUIREMENTS WITH KITCHEN EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.

ALL SINGLE-PHASE RECEPTACLES RATED 150V TO GROUND OR LESS, 50A OR LESS, AND THREE-PHASE RECEPTACLES RATED 150V TO GROUND OR LESS, 100A OR LESS SHALL HAVE GFCI PROTECTION PER 2017 NEC 210.8 (B) (2).

DESIGN CODES
 IECC, 2018 NEC, 2017


ELECTRICAL CONTRACTOR SHALL NOTIFY DESIGNER/ENGINEER PRIOR TO ANY DEVIATION FROM THIS SET OF ELECTRICAL DESIGN PLANS. ANY CHANGES TO THE DESIGN, IF APPROVED BY ENGINEER, WILL REQUIRE REVISIONS TO PLANS AND POSSIBLE ADDITIONAL SERVICE FEE.

Project Contact/Designer: **Chad Curry**
 Project #21112
HAWKINS DESIGN GROUP INC.
 ELECTRICAL CONSULTING ENGINEERS
 140 WEST HARVELL ROAD
 GILBERT, ARIZONA 85233
 PH. 480.613.9000 FAX. 480.613.9001
 EMAIL: chad@hawkinsdesign.com

All concepts, designs and data indicated on these drawings are the sole property of the Hawkins Design Group Inc. and shall not be used for any other purpose other than originally intended, without written permission of the engineer.

IF DRAWING IS NOT PLOTTED AT 24 X 36 THEY ARE NOT FULL SIZE

ELECTRICAL POWER PLAN
 SCALE: 3/16"=1'




NOTE:
 ALL ELECTRICAL EQUIPMENT, POWER AND ASSOCIATED ELECTRICAL COMPONENTS LOCATED ON SITE OR THE EXTERIOR OF BUILDING ARE EXISTING TO REMAIN UNTOUCHED. FIELD VERIFY EXISTING CONDITIONS PRIOR TO CONSTRUCTION AND NOTIFY ENGINEER OF ANY DISCREPANCIES.

NOTE:
 ALL EXISTING ELECTRICAL EQUIPMENT, POWER AND ASSOCIATED ELECTRICAL COMPONENTS NOT SHOWN ARE TO BE REMOVED. FIELD VERIFY EXISTING CONDITIONS PRIOR TO CONSTRUCTION AND NOTIFY ENGINEER OF ANY DISCREPANCIES.

NOTE:
 EXISTING WALK-IN COOLER AND FREEZER AND ALL ASSOCIATED COMPONENTS & ACCESSORIES TO REMAIN UNCHANGED.



WAWinton architects, inc.
 1110 E. Missouri Ave., Suite 800, Phoenix, Arizona 85014
 (602) 230-9778




REMODEL FOR RESTAURANT
 1564 E. FLORENCE BLVD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn CRC
 approved AG
 date 4/30/2021

revisions

E-2.0



- ### KEYED NOTES
- 1 LOW VOLTAGE SWITCH #1, REFER TO DETAIL FOR ADDITIONAL INFORMATION.
 - 2 EXISTING DIMMING LIGHTING CONTROL PANEL "D".
 - 3 DASHED AREA DENOTES DAYLIGHT CONTROL ZONE. LIGHT FIXTURES IN THIS AREA ARE INDEPENDENTLY CONTROLLED PER IECC 2018 AUTOMATIC DAYLIGHT CONTROLS SECTION C405.
 - 4 LOW VOLTAGE PHOTOCELL FOR DAYLIGHT ZONE CONTROL REQUIREMENTS PER IECC 2018. PHOTOCELL DEVICE SHALL BE TIED IN WITH POWER PACK(S), OCCUPANCY SENSOR(S) AND LOW VOLTAGE SWITCH(ES) AS REQUIRED PER DEVICE MANUFACTURER.
 - 5 WALL/CEILING MOUNTED OCCUPANCY SENSOR SHALL BE PROGRAMMED FOR AUTO ON/AUTO OFF MODE. TYPICAL.
 - 6 WALL/CEILING MOUNTED DUAL TECHNOLOGY OCCUPANCY SENSOR SHALL BE PROGRAMMED AS VACANCY SENSOR, MANUAL ON/AUTO OFF. TYPICAL.
 - 7 ALL EXISTING LIGHTING IN THIS AREA TO REMAIN UNCHANGED.

- ### GENERAL NOTES - LIGHTING
1. REFER TO ELECTRICAL SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND COMPLETE CONTRACTUAL OBLIGATIONS.
 2. THE ELECTRICAL CONTRACTOR SHALL (PRIOR TO HIS BID) VISIT THE SITE AND FIELD VERIFY ALL EXISTING CONDITIONS AND b) TAKE ALL CONSIDERATIONS INTO ACCOUNT AT THE TIME OF BID. NO CONSIDERATIONS WILL BE GRANTED THE CONTRACTOR AFTER THE BID IS ACCEPTED.
 3. ALL ELECTRICAL METALLIC TUBING (EMT), RIGID NON-METALLIC CONDUIT, FLEXIBLE METALLIC CONDUIT, FLEXIBLE NON-METALLIC CONDUITS, "SEALTIGHT" TYPE CONDUITS AND ALL OTHER CONDUITS THAT DO NOT CONTAIN A CODE SIZED GROUND WIRE SHALL HAVE A CODE SIZED BOND WIRE PER NEC TABLE 250.122 INSTALLED WITH THE CIRCUIT CONDUCTORS.
 4. ALL NIGHTLIGHT/EMERGENCY LIGHT (NL/EM) FIXTURES SHALL BE CONNECTED UNSWITCHED. IF NO EMERGENCY LIFE SAFETY SYSTEM IS INSTALLED (ie: GENERATOR, etc.), THE OUTER LAMPS SHALL BE CONNECTED UNSWITCHED TO LOCAL LIGHTING CIRCUIT AND CONNECTED VIA AN EMERGENCY BALLAST - 1400 LUMEN OR FULL LUMEN OUTPUT MINIMUM. PROVIDE NEW IF NOT ALREADY EXISTING.
 5. ALL FIXTURES INSTALLED OUTDOORS SHALL BE RATED FOR DAMP/WET LOCATIONS AS REQUIRED. THE CONTRACTOR SHALL COORDINATE DAMP/WET LOCATION RATING AND INSTALLATION PER NEC ARTICLE "FIXTURE LOCATIONS".
 6. ALL RECESSED LIGHT FIXTURES SHALL BE I.C. RATED OR A MINIMUM OF 3" FROM COMBUSTIBLE MATERIAL PER NEC ARTICLE "LUMINAIRES, LAMP HOLDERS AND LAMPS - CLEARANCE AND INSTALLATION".
 7. ELECTRICAL CONTRACTOR TO VERIFY A MINIMUM OF 1 FOOT-CANDLE AT 1 FOOT ABOVE FLOOR ALONG EXIT PATH PER IBC ARTICLE "MEANS OF EGRESS ILLUMINATION".
 8. LIGHT SWITCHES SHALL BE INSTALLED TO CONFORM TO NEC 404.8 ARTICLE "SWITCHES - ACCESSIBILITY AND GROUPING".
 9. ALL INDOOR FLUORESCENT FIXTURES WITH DOUBLE ENDED LAMPS SHALL HAVE INTEGRAL DISCONNECTS.
 10. J-BOXES INTENDED FOR THE USE OF SWITCHES CONTROLLING LIGHTING LOADS AND CONTAINING A GROUNDED GENERAL-PURPOSE BRANCH CIRCUIT FOR LIGHTING SHALL CONTAIN A NEUTRAL CONDUCTOR AS REQUIRED PER NEC 404.2.

IECC WATT PER SQUARE FOOT COMPLIANCE

DINING: FAMILY = 2954 s.f. x 0.71 W = 2098W
 FOOD PREPARATION = 1530 s.f. x 1.06 W = 1622W
 TOTAL AVAILABLE WATTS = 3720W

FIXT.	QTY	INPUT WATTS	SUB-TOTAL
A	19 x	50	= 950 W
B	53 x	23	= 1219 W
C	2 x	50	= 100 W
TOTAL WATTS USED =			2269 W
WATTS AVAILABLE =			3720 W
CODE COMPLIANCE BY =			1451 W


TABLE PROVIDED AS COMPLIANCE MATERIAL TO MEET IECC POWER ALLOWANCE. METHOD IS ACCEPTABLE PER IECC C101.5.1

LUMINAIRE SCHEDULE

1. PROVIDE 90-MINUTE EMERGENCY BATTERY BACK-UP FOR ALL EMERGENCY FIXTURES. SEE SCHEDULE BELOW FOR SPECIFICATIONS AND LUMEN REQUIREMENTS.
2. MODULAR WIRING SYSTEM FOR LIGHT FIXTURES IS AN ACCEPTABLE ALTERNATE.
3. BASE BID FOR LUMINAIRES SHALL BE BASED ON MANUFACTURERS LISTED IN CONTRACT DOCUMENTS. UPON AWARD OF PROJECT, ALTERNATES PROPOSED BY CONTRACTOR SHALL BE SUBMITTED WITH WRITTEN OWNER APPROVAL & AN ITEMIZED DEDUCT TO BASE BID.
4. ALTERNATE FIXTURE SELECTIONS MAY REQUIRE ADDITIONAL TIME FOR SUBMITTAL REVIEW & POSSIBLE ENGINEERING DESIGN CHANGES, TO BE BILLED TO THE CONTRACTOR.
5. PROVIDE MINIMUM 10 MINUTE TIME DELAY ON EMERGENCY FIXTURES WHEN HID AREA LIGHTING IS USED.

MARK	MANUFACTURER MODEL NUMBER	VOLTS	LAMPS CRI/CCT INPUT WATTS	REMARKS/MOUNTING
A	COLUMBIA LIGHTING CFP24-55_41_3435	MVOLT	LED 80/3500 SOW	2'x4' EDGE LIT FLAT PANEL RECESSED, DIMMABLE, WITH 90 MINUTE BATTERY BACK UP WHEN TAGGED EM.
B	PRESCOLITE LIGHTING LTC-6RD-P-20L35K 8XW-DM1-S-BL	MVOLT	LED 80/3500 23W	6" ROUND, RECESSED LED DOWNLIGHT, DIMMABLE, WITH 90 MINUTE BATTERY BACK UP WHEN TAGGED EM.
C	COLUMBIA LIGHTING MPS4-35XXXX-XXX-X	MVOLT	LED 80/3500 50W	4' LED MULTIPURPOSE LINEAR RIBBON LIGHT, DIMMABLE, WITH 90 MINUTE BATTERY BACK UP WHEN TAGGED EM.
Ⓢ	DUAL LITE LES SERIES	277	INCLUDED Ⓢ	EMERGENCY EXIT SIGN WITH 90 MINUTE BATTERY BACK UP.
Ⓢ	DUAL-LITE PGN Series	277	LED 75CRI/4000K 18W	WALL SCONCE, MOUNTING HEIGHT 8' WITH 90 MINUTE BATTERY BACK UP WHEN TAGGED EM.

* NOTE:
 LIGHTING FIXTURE PROVIDED BY FRANCHISEE AND INSTALLED BY E.C.



ELECTRICAL LIGHTING PLAN

SCALE: 3/16"=1'


DESIGN CODES
 IECC, 2018 NEC, 2017

ELECTRICAL CONTRACTOR SHALL NOTIFY DESIGNER/ENGINEER PRIOR TO ANY DEVIATION FROM THIS SET OF ELECTRICAL DESIGN PLANS. ANY CHANGES TO THE DESIGN, IF APPROVED BY ENGINEER, WILL REQUIRE REVISIONS TO PLANS AND POSSIBLE ADDITIONAL SERVICE FEE.

Project Contact/Designer: **Chad Curry**
 Project # 21112
HAWKINS DESIGN GROUP INC.
 ELECTRICAL CONSULTING ENGINEERS
 1140 WEST HARVELL ROAD
 GILBERT, ARIZONA 85233
 PH 480.813.9000 FAX 480.813.9001
 EMAIL: chad@hawkinsdesign.com

All concepts, designs and data indicated on these drawings are the sole property of the Hawkins Design Group Inc., and shall not be used for any other purpose other than originally intended without written permission of the engineer.

IF DRAWING IS NOT PLOTTED AT 24 X 36 THEY ARE NOT FULL SIZE



winton architects, inc.
 1110 E. Missouri Ave., Suite 800, Phoenix, Arizona 85014
 (602) 230-9778 FAX (602) 265-9739



REMODEL FOR RESTAURANT
 1564 E. FLORENCE BLVD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn CRC
 approved AG
 date 4/30/2021

revisions

E-3.0

GENERAL NOTES - HVAC


- REFER TO ELECTRICAL SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND COMPLETE CONTRACTUAL OBLIGATIONS.
- THE ELECTRICAL CONTRACTOR SHALL (PRIOR TO HIS BID) a) VISIT THE SITE AND FIELD VERIFY ALL EXISTING CONDITIONS AND b) TAKE ALL CONSIDERATIONS INTO ACCOUNT AT THE TIME OF BID. NO ADDITIONAL CONSIDERATIONS WILL BE GRANTED THE CONTRACTOR AFTER THE BID IS ACCEPTED.
- ALL ELECTRICAL METALLIC TUBING (EMT), RIGID NON-METALLIC CONDUIT, FLEXIBLE METALLIC CONDUIT, FLEXIBLE NON-METALLIC CONDUITS, "SEALTIGHT" TYPE CONDUITS AND ALL OTHER CONDUITS THAT DO NOT CONTAIN A CODE SIZED GROUND WIRE SHALL HAVE A CODE SIZED BOND WIRE PER NEC TABLE 250.122 INSTALLED WITH THE CIRCUIT CONDUCTORS.
- RECEPTACLES LOCATED WITHIN 6'-0" OF SINKS OR WATER SHALL BE CONNECTED EITHER TO A GROUND FAULT CIRCUIT INTERRUPTER TYPE CIRCUIT BREAKER OR TO A GROUND FAULT CIRCUIT INTERRUPTER TYPE RECEPT.
- PRIOR TO ROUGH-IN, THE ELECTRICAL CONTRACTOR SHALL COORDINATE THE EXACT LOCATION OF ALL HVAC UNITS AND SUPPLY AIR DUCT SMOKE DETECTORS WITH THE MECHANICAL DRAWINGS.
- PROVIDE ROOF TOP WEATHER PROOF / WEATHER RESISTANT G.F.C.I. WITHIN 25'-0" OF ALL ROOF TOP HVAC EQUIPMENT IN ACCORDANCE WITH NEC ARTICLE "HEATING, AIR-CONDITIONING AND REFRIGERATION EQUIPMENT OUTLET". THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR COORDINATION OF THESE RECEPTACLES IN THE FIELD REGARDLESS PLAN LAYOUT.
- ALL DISCONNECTS SHALL BE OF THE HEAVY DUTY TYPE AND FUSED PER THE NAMEPLATE RATING OF THE HVAC UNIT OR MOTOR.
- THE EC SHALL - PRIOR TO ROUGH-IN, FIELD VERIFY ALL HVAC VOLTAGES AND AMPERAGES AGAINST PLAN REQUIREMENTS. FAILURE TO VERIFY AND NOTIFY ENGINEER / ARCHITECT PRIOR TO ROUGH-IN SHALL INDICATE THAT THE EC SHALL ASSUME ALL RESPONSIBILITY FOR DESIGN AND INSTALLATION REQUIREMENTS.
- THE ELECTRICAL CONTRACTOR SHALL ENSURE FINAL COORDINATION OF THE MANUFACTURERS RECOMMENDED FUSE SIZE FOR HVAC EQUIPMENT WITH THE SIZE DISCONNECT PRIOR TO OR DURING ROUGH-IN. ADVISE ENGINEER IF CHANGES IN THE FINAL SELECTION OF HVAC EQUIPMENT HAVE IMPACTED DISCONNECT, BREAKER, OR CONDUCTOR SIZE.
- ALL ROOF TOP UNITS EXPOSED TO AMBIENT TEMPERATURES AND WEATHER SHALL HAVE NEMA 3R MINIMUM RATED DISCONNECTS.
- MAXIMUM TAP CONDUCTOR LENGTH SHALL BE 25'-0" PER NEC ARTICLE 240 "FEEDER TAPS" AND "TRANSFORMER SECONDARY CONDUCTORS" AND SHALL NOT BE SMALLER THAN 1/3 THE AMPACITY OF FEEDER CONDUCTORS.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH MECHANICAL CONTRACTOR AND FIRE ALARM CONTRACTOR REGARDING SMOKE DUCT DETECTORS TO INCLUDE PURCHASE, INSTALLATION, AND FINAL CONNECTIONS.
- THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO COORDINATE WITH THE OWNER OR OTHER SUPPLIERS REGARDING ANY REQUIREMENTS FOR MOTOR STARTERS IN ADDITION TO THAT WHICH IS INDICATED FOR THE HVAC SYSTEM. THIS INCLUDES FURNISH AND INSTALL STARTERS TO INTERFACE WITH ANY ENERGY MANAGEMENT SYSTEM OR OTHER SPECIAL SYSTEMS.
- ELECTRICAL CONTRACTOR SHALL PROVIDE CORRECT SIZE / TYPE / VOLTAGE / QUANTITY OF DUAL-ELEMENT, TIME-DELAY FUSE(S) SIZED PER HVAC EQUIPMENT MANUFACTURER UNLESS OTHERWISE SPECIFIED BY UNIT NAMEPLATE / MANUFACTURER DATA.

SYMBOL LEGEND

- X - EXISTING TO BE DEMOLISHED
 - EM - EMERGENCY LIGHT
 - E - EXISTING TO REMAIN UNCHANGED
 - R - RELOCATED TO LOCATION AS SHOWN, EXTEND EXISTING CONDUIT AND CONDUCTORS AS SHOWN.
 - N - NEW ELECTRICAL DEVICE (UNMARKED DEVICES ARE TO BE CONSIDERED NEW)
- NOTE: NOT ALL SYMBOLS ARE USED.

KEYED NOTES

- PROVIDE HVAC MAINTENANCE W.P. GFCI PER NEC SECTION 210.63 WITH WHILE-IN-USE COVER AND OUTLET BOX HOOD SHALL BE LISTED AND IDENTIFIED AS "EXTRA-DUTY" PER NEC 406.9(D)(1). TIE INTO CIRCUIT "KA-1"-9.



ELECTRICAL HVAC PLAN
 SCALE: 3/16"=1'

DESIGN CODES
 IECC, 2018 NEC, 2017

ELECTRICAL CONTRACTOR SHALL NOTIFY DESIGNER/ENGINEER PRIOR TO ANY DEVIATION FROM THIS SET OF ELECTRICAL DESIGN PLANS. ANY CHANGES TO THE DESIGN, IF APPROVED BY ENGINEER, WILL REQUIRE REVISIONS TO PLANS AND POSSIBLE ADDITIONAL SERVICE FEE.

Project Contact/Designer: **Chad Curry**
 Project # 21112


HAWKINS DESIGN GROUP INC.
 ELECTRICAL CONSULTING ENGINEERS
 140 WEST HARWEL ROAD
 GILBERT, ARIZONA 85233
 PH 480.913.9000 FAX 480.913.9001
 EMAIL email@hawkinsdsg.com

All concepts, designs and data indicated on these drawings are the sole property of the Hawkins Design Group Inc., and shall not be used for any other purpose other than originally intended without written permission of the engineer.

IF DRAWING IS NOT PLOTTED AT 24 X 36 THEY ARE NOT FULL SIZE



WAW winton architects, inc.
 1110 E. Missouri Ave., Suite 800, Phoenix, Arizona 85014
 (602) 230-9778 FAX (602) 265-9739



REMODEL FOR RESTAURANT
 1564 E. FLORENCE BLVD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn CRC
 approved AG
 date 4/30/2021

revisions

E-4.0

EXIST. PANELBOARD SCHEDULE 'KA-1'

TYPE: PANELBOARD	NEMA TYPE: NEMA 1	MAIN TYPE: FEED THRU	M.L.O. NO
VOLTAGE: 208Y/120V 3Ø 4W	AF: 44,034	ISO. GROUND: NO	YES
MOUNTING: SURFACE	C/B RATING: 10,000	SERVICE RATED: NO	NO
BUS AMPS: 400	C/B A.I.C.: 10,000		

PROVIDE GFCI CIRCUIT BREAKER PROVIDE TIE BAR EXIST. TO REMAIN UNCHANGED

HANDLE "LOCK-ON" DEVICE CIRCUIT VIA LTG CONTROLS EXIST. WITH CHANGED LOAD

HANDLE "LOCK-OFF" DEVICE EXIST. W/ ALL LOAD REMOVED NEW BREAKER WITH NEW LOAD

R = RECEIPTS H = H.V.A.C. E = EQUIP. K = KITCHEN M = MISC. L = CONT. LIGHTING C = CONT. EQUIP.

T	AREA SERVED	C/B	#	A#	B#	C#	C/B	T	AREA SERVED
△	K WALK-IN FREEZER	E1	20	1	720	2	20	1	K CONVECTION OVEN
△	K EVAPORATOR	E2	20	3	800	4	20	1	- SHUNT TRIP
△	K REMOTE CONDENSER UNIT	E3	25	3	2080	6	20	1	- SPARE
	R RECEIPTS - ROOF TOP		20	9	540	8	20	1	K ICE MACHINE, 1600 LB.
△	K SODA DISPENSER	E5	20	11	480	12	20	3	- SPARE
△	K COFFEE/TEA BREWER	E6	20	13	1524	14	20	1	K REMOTE CONDENSER UNIT
△	K DISHWASHER, CONVEYOR	E4	20	15	6605	16	20	1	- SPARE
	- SHUNT TRIP		20	17	6605	16	20	1	K REACH-IN FRIDGE #1
			20	19	6605	16	20	1	K RICE COOKER
			20	21	1124	22	20	1	- SPARE
△	K REACH-IN FRIDGE #3	E13	20	23	336	24	20	1	K REACH-IN FRIDGE #2
△	K REFRIGERATOR STAND	E14	20	25	396	26	20	1	K COLD FOOD WELL
	- SHUNT TRIP		20	27	2496	28	20	1	K HOT FOOD WELL #1
	- SPARE		20	29	2496	30	20	1	- SPARE
△	K HOT FOOD WELL #3	E18	30	33	2496	34	30	1	K HOT FOOD WELL #2
	- SPARE		30	35	1664	36	30	1	- SPARE
△	E WALK-IN COOLER ACCESSORIES	E19	20	37	1920	38	20	1	- SPARE
△	K HOT FOOD WELL #4	E18	30	39	2496	40	30	1	- SPARE
	- SPARE		30	41	2496	42	30	1	- SPARE

NON-CONTINUOUS LOAD 16049 18021 19325 19325 VA / 120 V = 161.0 AMPS
 CONTINUOUS LOAD 0 0 0 0 VA / 120 V = 0.0 AMPS
 CONTINUOUS LOAD @ 25% 0 0 0 0 VA / 120 V = 0.0 AMPS
 TOTAL LOAD PER PHASE 16049 18021 19325 VA / 120 V = 161.0 AMPS

NOTE:
 1. KITCHEN LOAD TAKEN AT 65% PER NEC.
 2. CONTRACTOR TO VERIFY SERIES RATING, AFC AND C/B A.I.C. NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.
 3. LARGER 2 AND 3 POLE GFCI BREAKERS MAY NOT BE AVAILABLE IN WHICH CASE IN-LINE GFCI TRIP UNITS MUST BE PROVIDED.
 4. ALL NEW CIRCUIT BREAKERS SHALL MATCH EXISTING CIRCUIT BREAKERS MANUFACTURERS AND TYPE.

EXIST. PANELBOARD SCHEDULE 'KA-2'

TYPE: PANELBOARD	NEMA TYPE: NEMA 1	MAIN TYPE: FEED THRU	M.L.O. NO
VOLTAGE: 208Y/120V 3Ø 4W	AF: 42,292	ISO. GROUND: NO	NO
MOUNTING: SURFACE	C/B RATING: 10,000	SERVICE RATED: NO	NO
BUS AMPS: 400	C/B A.I.C.: 10,000		

PROVIDE GFCI CIRCUIT BREAKER PROVIDE TIE BAR EXIST. TO REMAIN UNCHANGED

HANDLE "LOCK-ON" DEVICE CIRCUIT VIA LTG CONTROLS EXIST. WITH CHANGED LOAD

HANDLE "LOCK-OFF" DEVICE EXIST. W/ ALL LOAD REMOVED NEW BREAKER WITH NEW LOAD

R = RECEIPTS H = H.V.A.C. E = EQUIP. K = KITCHEN M = MISC. L = CONT. LIGHTING C = CONT. EQUIP.

T	AREA SERVED	C/B	#	A#	B#	C#	C/B	T	AREA SERVED
△	K MERCH. REFRIGERATOR	E19	20	1	728	2	20	1	K REACH-IN FRIDGE #4
			20	3	960	4	20	1	K COLD SLAB #1
			35	5	3003	6	20	1	K COLD SLAB #2
△	K SOFT SERVE MACHINE	E20	20	7	3003	8	20	1	K COLD SLAB #3
			20	9	960	10	20	1	K COLD SLAB #4
△	K SYRUP TANK RACK	E21	20	11	1320	12	20	1	K COLD SLAB #5
△	K PREP REFRIGERATOR	E25	20	13	1440	14	20	1	K COLD SLAB #6
△	K HOOD - LARGE WOK	E26	20	15	960	16	20	1	C EXHAUST FAN - KEF-5
	- SHUNT TRIP		20	17	795	18	20	1	- SHUNT TRIP
△	K HOOD - SMALL WOK	E27	20	19	960	20	20	1	E WATER HEATER - WH-1
	- SHUNT TRIP		20	21	1920	22	20	1	H CIRCULATION PUMP - CP-1
△	K HOOD - ISLAND	E28	20	23	960	24	20	1	- SPARE
	- SHUNT TRIP		20	25	960	26	20	1	- SPARE
	- SHUNT TRIP		20	27	960	28	20	1	- SPARE
△	-HOOD - MONGOLIAN	E29	20	29	960	30	20	1	- SPARE
	- SHUNT TRIP		20	31	960	32	20	1	- SPARE
	- SHUNT TRIP		20	33	960	34	20	1	- SPARE
	- SPARE		20	35	960	36	20	1	- SPARE
	- SPARE		20	37	960	38	20	1	- SPARE
	- SPARE		20	39	960	40	20	1	- SPARE
	- SPARE		20	41	960	42	20	1	- SPARE

NON-CONTINUOUS LOAD 10835 8099 7683 10835 VA / 120 V = 90.3 AMPS
 CONTINUOUS LOAD 0 756 0 756 VA / 120 V = 6.3 AMPS
 CONTINUOUS LOAD @ 25% 0 189 0 189 VA / 120 V = 1.6 AMPS
 TOTAL LOAD PER PHASE 10835 9044 7683 10835 VA / 120 V = 90.3 AMPS

NOTE:
 1. KITCHEN LOAD TAKEN AT 65% PER NEC.
 2. CONTRACTOR TO VERIFY SERIES RATING, AFC AND C/B A.I.C. NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.
 3. LARGER 2 AND 3 POLE GFCI BREAKERS MAY NOT BE AVAILABLE IN WHICH CASE IN-LINE GFCI TRIP UNITS MUST BE PROVIDED.
 4. ALL NEW CIRCUIT BREAKERS SHALL MATCH EXISTING CIRCUIT BREAKERS MANUFACTURERS AND TYPE.

EXIST. PANELBOARD SCHEDULE 'A'

TYPE: PANELBOARD	NEMA TYPE: NEMA 1	MAIN TYPE: FEED THRU	M.L.O. NO
VOLTAGE: 208Y/120V 3Ø 4W	AF: 46,033	ISO. GROUND: NO	YES
MOUNTING: SURFACE	C/B RATING: 10,000	SERVICE RATED: NO	NO
BUS AMPS: 225	C/B A.I.C.: 10,000		

PROVIDE GFCI CIRCUIT BREAKER PROVIDE TIE BAR EXIST. TO REMAIN UNCHANGED

HANDLE "LOCK-ON" DEVICE CIRCUIT VIA LTG CONTROLS EXIST. WITH CHANGED LOAD

HANDLE "LOCK-OFF" DEVICE EXIST. W/ ALL LOAD REMOVED NEW BREAKER WITH NEW LOAD

R = RECEIPTS H = H.V.A.C. E = EQUIP. K = KITCHEN M = MISC. L = CONT. LIGHTING C = CONT. EQUIP.

T	AREA SERVED	C/B	#	A#	B#	C#	C/B	T	AREA SERVED
△	L LIGHTING - DINING ROOM		20	1	1219	2	20	1	- SPARE
△	L LIGHTING - FOOD PREP		20	3	1050	4	20	1	M TMB
△	R RECEIPTS - OFFICE		20	5	800	6	20	1	- SPARE
	- SPARE		20	7	500	8	20	1	- SPARE
	- SPARE		20	9	500	10	20	1	M FAC
	- SPARE		20	11	1200	12	20	1	R RECEIPTS - ROOF
	- SPARE		20	13	1200	14	20	1	R RECEIPTS - ROOF
	- SPARE		20	15	1500	16	20	1	L BUILDING SIGNAGE
	- SPARE		20	17	1500	18	20	1	L BUILDING SIGNAGE
	- SPARE		20	19	1050	20	20	1	L EXT. BLDG LIGHTING
	- SPARE		20	21	1050	22	20	1	L EXT. FLOOD LIGHTING
	- SPARE		20	23	600	24	20	1	- SPARE
△	R RECEIPTS - LOBBY		20	25	1200	26	20	1	- SPARE
△	R RECEIPTS - EXTERIOR		20	27	1400	28	20	1	- SPARE
△	R RECEIPTS - RESTROOMS		20	29	800	30	20	1	L FEESTON LIGHTS (PATIO)
	- SPARE		20	31	500	32	20	1	- SPARE
	- SPARE		20	33	500	34	20	1	- SPARE
	- SPARE		20	35	1683	36	20	1	- SPARE
	- SPARE		20	37	400	38	20	1	- SPARE
	- SPARE		20	39	1695	40	20	1	- SPARE
	- SPARE		20	41	1260	42	20	1	- SPARE

NON-CONTINUOUS LOAD 2400 2900 2900 2900 VA / 120 V = 24.2 AMPS
 CONTINUOUS LOAD 2669 4845 4943 4943 VA / 120 V = 41.2 AMPS
 CONTINUOUS LOAD @ 25% 667 1211 1236 1236 VA / 120 V = 10.3 AMPS
 TOTAL LOAD PER PHASE 5736 8956 9079 9079 VA / 120 V = 75.7 AMPS

NOTE:
 1. EXISTING LOADS TAKEN FROM PREVIOUSLY RECORDED DOCUMENTS PREPARED BY PURDY - MCGUIRE. ELECTRICAL CONTRACTOR SHALL NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.
 2. ALL NEW CIRCUIT BREAKERS SHALL MATCH EXISTING CIRCUIT BREAKERS MANUFACTURERS AND TYPE.
 3. CONTRACTOR TO VERIFY SERIES RATING, AFC AND C/B A.I.C. NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.

EXIST. PANELBOARD SCHEDULE 'M'

TYPE: PANELBOARD	NEMA TYPE: NEMA 1	MAIN TYPE: FEED THRU	M.L.O. NO
VOLTAGE: 208Y/120V 3Ø 4W	AF: 44,647	ISO. GROUND: NO	NO
MOUNTING: SURFACE	C/B RATING: 10,000	SERVICE RATED: NO	NO
BUS AMPS: 400	C/B A.I.C.: 66,000		

PROVIDE GFCI CIRCUIT BREAKER PROVIDE TIE BAR EXIST. TO REMAIN UNCHANGED

HANDLE "LOCK-ON" DEVICE CIRCUIT VIA LTG CONTROLS EXIST. WITH CHANGED LOAD

HANDLE "LOCK-OFF" DEVICE EXIST. W/ ALL LOAD REMOVED NEW BREAKER WITH NEW LOAD

R = RECEIPTS H = H.V.A.C. E = EQUIP. K = KITCHEN M = MISC. L = CONT. LIGHTING C = CONT. EQUIP.

T	AREA SERVED	C/B	#	A#	B#	C#	C/B	T	AREA SERVED
△	C RTU-1		100	1	9960	2	20	1	H EF-1
			35	3	9960	4	20	1	- SPARE
			35	5	9960	6	20	1	- SPARE
△	H RTU-2		35	7	4200	8	20	1	H EXHAUST FAN - KEF-1
			20	9	997	10	20	1	- SPARE
			20	11	4200	12	20	1	- SPARE
△	H RTU-3		40	13	3720	14	20	1	- SHUNT TRIP
			20	15	1141	16	20	1	- SPARE
△	H RTU-4		20	17	3720	18	20	1	H EXHAUST FAN - KEF-2
			20	19	1141	20	20	1	- SHUNT TRIP
△	H EF-4		20	21	696	22	20	1	- SPARE
△	H EF-5		20	23	696	24	20	1	- SHUNT TRIP
△	R ROOF RECEIPTS		20	25	720	26	20	1	- SPARE
			35	27	1903	28	20	1	H EXHAUST FAN - KEF-3
			27	29	312	30	20	1	- SPARE
△	H MAKE UP AIR UNIT - MAU-1		20	31	1903	32	20	1	- SHUNT TRIP
			20	33	312	34	20	1	- SPARE
△	H MAKE UP AIR UNIT - MAU-2		15	35	798	36	20	1	H EXHAUST FAN - KEF-4
			20	37	1141	38	20	1	- SPARE
	- SPARE		20	39	798	40	20	1	- SPARE
	- SPARE		20	41	1141	42	20	1	- SPARE
	- SPARE		20	43	1600	44	20	1	- SPARE

NON-CONTINUOUS LOAD 15808 15808 17432 17432 VA / 120 V = 145.3 AMPS
 CONTINUOUS LOAD 9960 9960 9960 9960 VA / 120 V = 83.0 AMPS
 CONTINUOUS LOAD @ 25% 2490 2490 2490 2490 VA / 120 V = 20.8 AMPS
 TOTAL LOAD PER PHASE 28258 28258 29882 29882 VA / 120 V = 249.0 AMPS

NOTE:
 1. EXISTING LOADS TAKEN FROM PREVIOUSLY RECORDED DOCUMENTS PREPARED BY PURDY - MCGUIRE. ELECTRICAL CONTRACTOR SHALL NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.
 2. ALL NEW CIRCUIT BREAKERS SHALL MATCH EXISTING CIRCUIT BREAKERS MANUFACTURERS AND TYPE.
 3. CONTRACTOR TO VERIFY SERIES RATING, AFC AND C/B A.I.C. NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.

EXIST. PANELBOARD SCHEDULE 'KB'

TYPE: PANELBOARD	NEMA TYPE: NEMA 1	MAIN TYPE: FEED THRU	M.L.O. NO
VOLTAGE: 208Y/120V 3Ø 4W	AF: 46,033	ISO. GROUND: NO	NO
MOUNTING: SURFACE	C/B RATING: 10,000	SERVICE RATED: NO	NO
BUS AMPS: 225	C/B A.I.C.: 10,000		

PROVIDE GFCI CIRCUIT BREAKER PROVIDE TIE BAR EXIST. TO REMAIN UNCHANGED

HANDLE "LOCK-ON" DEVICE CIRCUIT VIA LTG CONTROLS EXIST. WITH CHANGED LOAD

HANDLE "LOCK-OFF" DEVICE EXIST. W/ ALL LOAD REMOVED NEW BREAKER WITH NEW LOAD

R = RECEIPTS H = H.V.A.C. E = EQUIP. K = KITCHEN M = MISC. L = CONT. LIGHTING C = CONT. EQUIP.

T	AREA SERVED	C/B	#	A#	B#	C#	C/B	T	AREA SERVED
△	K EBSA (WALK-IN FREEZER COMP)		20	1	1860	2	20	1	K EBSA (WALK-IN COOLER COMP)
			20	3	1056	4	20	1	- SPARE
			20	5	1860	6	20	1	- SPARE
			20	7	1716	8	20	1	K EBSA (COOLER COILS)
			20	9	1008	10	20	1	L E888 (LIGHTS)
			20	11	1716	12	20	1	R RECEIPTS - KITCHEN (a)
			20	13	2080	14	20	1	R RECEIPTS - KITCHEN (b)
			20	15	1200	16	20	1	R RECEIPTS - KITCHEN (c)
			20	17	2080	18	20	1	R RECEIPTS - KITCHEN (d)



WAW winton architects, inc.
 1110 E. Missouri Ave., Suite 800, Phoenix, Arizona 85014
 (602) 230-9778 FAX (602) 265-9739

REMODEL FOR RESTAURANT
 1564 E. FLORENCE BLVD.
 CASA GRANDE, ARIZONA
 LOGOS BUILDERS SOUTHWEST

job no. 20118
 drawn CRC
 approved AG
 date 4/30/2021

revisions

E-5.0

KEYED NOTES

- 1 EXISTING UNDERGROUND PRIMARY CONDUITS TO UTILITY COMPANY PAD MOUNTED TRANSFORMER.
- 2 EXISTING UTILITY Co. PAD MOUNTED TRANSFORMER.
- 3 EXISTING UNDERGROUND SECONDARY CONDUITS TO UTILITY COMPANY PAD MOUNTED TRANSFORMER.
- 4 EXISTING BONDING AND GROUNDING.
- 5 EXISTING CONDUIT AND CONDUCTOR TO REMAIN.
- 6 EXISTING DIMMING LIGHTING CONTROL PANEL "D". COORDINATE EXACT PROGRAMMING AND RELAY SWITCH LOCATIONS PRIOR TO ROUGH-IN. CONTRACTOR TO VERIFY MINIMUM 22k SCCR.

GENERAL NOTES - ONE-LINE

1. THE ELECTRICAL CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS TO FULLY FAMILIARIZE HIMSELF WITH ALL EXISTING CONDITIONS PRIOR TO BID. NO ADDITIONAL CONSIDERATIONS WILL BE ALLOWED AFTER THE BID.
2. THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR INSTALLING ALL INDICATED EQUIPMENT TO CODE COMPLIANT CLEARANCES. PROVIDE SUBMITTALS AS INDICATED IN SPECIFICATIONS TO PROPERLY COORDINATE PHYSICAL LOCATIONS OF NEW AND/OR EXISTING EQUIPMENT.
3. REFER TO ELECTRICAL SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND COMPLETE CONTRACTUAL OBLIGATIONS.
4. ALL DASHED LINES ARE INDICATING EXISTING EQUIPMENT.
5. THE ELECTRICAL CONTRACTOR SHALL PROVIDE CIRCUIT DIRECTORY OR CIRCUIT IDENTIFICATION FOR PANELBOARDS AND SOURCE OF SUPPLY FOR SWITCHBOARDS AND PANELBOARDS SUPPLIED BY A FEEDER IN OTHER THAN ONE-TWO-FAMILY DWELLINGS IN ACCORDANCE WITH NEC 408.4(A)&(B).
6. WHERE A RACEWAY ENTERS A BUILDING OR STRUCTURE FROM AN UNDERGROUND DISTRIBUTION SYSTEM, ELECTRICAL CONTRACTOR SHALL PROVIDE RACEWAY SEALS PER NEC 225.27.
7. THE ELECTRICAL CONTRACTOR SHALL PROVIDE FOR AND COORDINATE ALL TESTING AND INSPECTIONS REQUIRED BY THE AUTHORITY HAVING JURISDICTION, AND SHALL PROVIDE WRITTEN REPORTS TO THE ENGINEER OF ALL TEST RESULTS AND INSPECTION REPORTS FOR THIS DISCIPLINE.
8. WHERE SPECIAL INSPECTION/OBSERVATION IS REQUIRED, QUALIFIED 3RD PARTY INDIVIDUALS ACCEPTABLE TO THE AUTHORITY HAVING JURISDICTION SHALL WORK DIRECTLY FOR THE OWNER TO PERFORM ALL REQUIRED TESTING & INSPECTION.
9. UPON SUBSTANTIAL COMPLETION, THE ELECTRICAL CONTRACTOR SHALL NOTIFY THE ENGINEER AND SHALL ALLOW, AT THE ENGINEER'S DISCRETION, FOR THE INSPECTION OF NEW WORK PRIOR TO ENERGIZING.
10. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ARC-FLASH HAZARD WARNING FIELD LABELING TO ELECTRICAL EQUIPMENT IN ACCORDANCE WITH NEC 110.16.
11. THE ELECTRICAL CONTRACTOR SHALL PROVIDE MAXIMUM AVAILABLE FAULT CURRENT FIELD LABELING TO SERVICE EQUIPMENT INSTALLED IN OTHER THAN DWELLING UNITS IN ACCORDANCE WITH NEC 110.24.
12. GFP MUST BE ON-SITE TESTED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. ELECTRICAL CONTRACTOR SHALL PROVIDE COPY OF MANUFACTURER'S INSTRUCTIONS AND TEST RESULTS TO AUTHORITY HAVING JURISDICTION.
13. ALL EQUIPMENT RATED @ 1000 AMPS OR MORE SHALL BE TESTED IN CONFORMANCE WITH UL STANDARD 869 OR 891 FOR INSULATION BREAKDOWN PRIOR TO ITS BEING ENERGIZED. THIS TEST SHALL BE PERFORMED BY A TESTING FACILITY APPROVED BY THE BUILDING OFFICIAL. (SEE SECTION 4.6 OF ELECTRICAL SYSTEM SPECIFICATIONS)

FAULT CALCULATIONS

The following calculations are based on the "Point-to-Point" method

Three Phase: $f = \frac{\sqrt{3} \times L \times I_{sc}}{C \times V_p}$ Single Phase: $f = \frac{2 \times L \times I_{sc}}{C \times V_p}$ Three Phase Xfmr: $f = \frac{\sqrt{3} \times I_{sc} \times V_p \times \sqrt{Z}}{100,000 \times kVA}$ Single Phase Xfmr: $f = \frac{I_{sc} \times V_p \times \sqrt{Z}}{100,000 \times kVA}$

$M = 1/(1+f)$ $M = 1/(1+f)$ $I_{sc} = \frac{V_p \times M \times I_{sc}}{V_s}$ $I_{sc} = \frac{V_p \times M \times I_{sc}}{V_s}$


NOTE:
 CONDUCTOR LENGTHS SHOWN ARE SHORTEST-PATH FOR USE IN CALCULATIONS ONLY AND ARE NOT INTENDED FOR USE IN BIDDING OR CONSTRUCTION. ACTUAL LENGTHS MUST BE MEASURED & VERIFIED BY THE CONTRACTOR, AND REPORTED TO ENGINEER IF DESIGN CHANGES ARE REQUIRED.

Seq	SOURCE	Isc1	C	(SETS) OF WIRE SIZE	Typ.	C' VALUE	Vp(Vs)	#	L' feet	Xfmr kVA	Xfmr XZ	Isc2
1	SES	53011	NM	(3) OF #500 KCMIL	Cu.	26706	208	3	16	N/A	N/A	48716
2	MDP	48716	NM	(1) OF #3/0's	Cu.	13923	208	3	2	N/A	N/A	46033
3	MDP	48716	NM	(1) OF #3/0's	Cu.	13923	208	3	2	N/A	N/A	46033
4	MDP	48716	NM	(1) OF #500 KCMIL	Cu.	26706	208	3	6	N/A	N/A	44647
5	MDP	48716	NM	(1) OF #500 KCMIL	Cu.	26706	208	3	7	N/A	N/A	44034
6	MDP	48716	NM	(1) OF #500 KCMIL	Cu.	26706	208	3	10	N/A	N/A	42292
7	MDP	48716	NM	(1) OF #4's	Cu.	3826	208	3	15	N/A	N/A	18806

- NOTES:
1. EXISTING FAULTS TAKEN FROM PREVIOUSLY RECORDED DOCUMENTS PREPARED BY MEP CONSULTING. ELECTRICAL CONTRACTOR SHALL NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.
 2. CONTRACTOR TO VERIFY CONDUCTOR SIZE, WORST CASE SCENARIO USED FOR FAULT CALCULATION. NOTIFY ENGINEER IMMEDIATELY OF ANY DISCREPANCIES.

S.E.S. LOAD SUMMARY

CONNECTED LOAD ON PANEL "KA-1"	=	58003 VA
CONNECTED LOAD ON PANEL "KA-2"	=	32533 VA
CONNECTED LOAD ON PANEL "KB"	=	33577 VA
CONNECTED LOAD ON PANEL "A"	=	27273 VA
CONNECTED LOAD ON PANEL "M"	=	89707 VA
CONNECTED LOAD ON PANEL "D"	=	72054 VA
TOTAL REVISED LOAD ON S.E.S.	=	313147 VA
TOTAL REVISED LOAD ON S.E.S. @ 208V 3φ	=	870 A



ELECTRICAL ONE-LINE DIAGRAM
 SCALE: N.T.S.

DESIGN CODES
 IECC, 2018 NEC, 2017

ELECTRICAL CONTRACTOR SHALL NOTIFY DESIGNER/ENGINEER PRIOR TO ANY DEVIATION FROM THIS SET OF ELECTRICAL DESIGN PLANS. ANY CHANGES TO THE DESIGN, IF APPROVED BY ENGINEER, WILL REQUIRE REVISIONS TO PLANS AND POSSIBLE ADDITIONAL SERVICE FEE.

Project Contact/Designer: **Chad Curry**
 Project # 21112

HAWKINS DESIGN GROUP INC.
 ELECTRICAL CONSULTING ENGINEERS
 190 WEST HARWELL ROAD
 CLERK, ARIZONA 85233
 PH 480.913.9000 FAX 480.913.9001
 EMAIL: email@hawkinsdesign.com

All concepts, designs and data indicated on these drawings are the sole property of the Hawkins Design Group Inc. and shall not be used for any other purpose other than originally intended without written permission of the engineer.

IF DRAWING IS NOT PLOTTED AT 24 X 36 THEY ARE NOT FULL SIZE