



STORAGE SHED LIGHT FIXTURE WITH SPRING WOUND SPST 15 AMPERE TIME SWITCH IN SINGLE GANG BOX AND COVER PLATE. INTERMEDIATE #PFSM.

MP JAIL/CC JAIL TO THE LIGHT CONTROLS.

KB-10 REFER TO SHEET E-2

KB-12 PROVIDE OF BALLAST REFER TO SHEET E-2

01 FLOOR PLAN — LIGHTING
SCALE 1/4" = 1'-0"

- KEYED NOTES:**
- 1 CONNECT HOT LEG TO BATTERY IN EMERGENCY LIGHTS & EXIT SIGN TO KEEP CHARGE ON BATTERY. CONNECT TO NON-DIM MODULE IN DIMMER PANEL TO AREA OF DIMMER.
 - 2 CONNECT HOT LEG TO BATTERY IN EMERGENCY FIXTURES TO MAINTAIN BATTERY CHARGE ON SWITCHED FIXTURES.
 - 3 CONTRACTOR SHALL WIRE EXTERIOR LIGHT FIXTURES THRU LIGHTING CONDUCTORS TO DIMMER PANEL TIME SWITCHES. (REFER TO 02/E3 & 02/E4).
 - 4 CONTRACTOR TO SWITCH TYPE "3"-3" LIGHT FIXTURE AT INSIDE OF EXTERIOR ACCESS DOOR CLOSEST TO LIGHT FIXTURE LOCATION. REFER TO PLAN M6.2 FOR ACCESS DOOR LOCATIONS.

Xref: XTBLK50.dwg

E-1