



**KEYED NOTES:**

- 1) 12" W x 1 1/2" H x 6" D WP TELEPHONE SERVICE PULLBOX MOUNTED ON EXTERIOR WALL.
- 2) RECEPTACLE FOR RECIRCULATING PUMP. VERIFY LOCATION AND BOARDING HEIGHT.
- 3) POINT OF SET-UP FOR CABLE CONDUIT. (ONE (1) 2" E.C. WITH PULLBURE). VERIFY LOCATION. RUN TO PULL-BOX ABOVE CEILING. COORDINATE WITH CABLE CO.
- 4) RECEPTACLE FOR FLY FAN MOUNTED ABOVE DOOR. VERIFY BOARDING HEIGHT. MAKE ALL FINAL CONNECTIONS.
- 5) FIRE ALARM (ADVISED). REFER TO SHEET FS-1 FOR EXACT IDENTIFICATION, LOCATION AND MOUNTING HEIGHTS. E.C. WITH PULLBURE TO ABOVE CEILING. (TYPICAL)
- 6) 3/4" CONDUIT WITH PULLBURE TO EACH COMMUNICATION DEVICE. (TYPICAL)
- 7) RECEPTACLE AND TV OUTLET +84" AFF (VERIFY LOCATION WITH OWNER).
- 8) HOOD CONTROL PANEL. PROVIDE WIRING TO EX-1,2,3,4 & 5F-11. CONDUIT TO ABOVE FIRE SYSTEM. HOOD FAN SWITCH. REFER TO FLOOR DRAWING FOR WIRING DIAGRAM.
- 9) 3/4" E.C. WITH PULLBURE TO ABOVE CEILING (FOR SOUND SYSTEM CONTROL).
- 10) DISH MACHINE (EV-5) TO BE INTERLOCKED WITH HOOD CONTROL SWITCH FOR ON/OFF OPERATION. COORDINATE LOCATION OF DISCONNECTS, WITH EQUIPMENT MANUFACTURER.
- 11) L.V. TRANSFORMER AND SERVICE BUZZER WALL MOUNT AT 84" AFF. FURNISH AND INSTALL CONTROL WIRING IN CONDUIT AND ALL FINAL CONNECTIONS TO PUSH-BUTTON AT RECEIVING GATE.
- 12) FINE SWITCH ON HOOD. PROVIDE WIRING TO HOOD CONTROL PANEL.
- 13) GFI RECEPTACLE TO OWNER PROVIDED METER.

**GENERAL NOTES:**

- A. A COMPLETE FIRE ALARM SYSTEM AS REQUIRED BY NFPA AND LOCAL FIRE MARSHALL TO BE PROVIDED BY OWNER UNDER SEPARATE CONTRACT. THE ELECTRICAL CONTRACTOR SHALL PROVIDE AND INSTALL ALL ROUGH IN PER FIRE ALARM CONTRACTOR'S SHOP DRAWING.
- B. REFER TO "K" DRAWINGS FOR ADDITIONAL KITCHEN EQUIPMENT INFORMATION. VERIFY ALL ELECTRICAL REQUIREMENTS AND DEVICE LOCATION AND TIE-IN WITH EQUIPMENT SUPPLIER PRIOR TO INSTALLATION. FURNISH AND INSTALL POWER AND CONTROL WIRING AND ALL FINAL CONNECTIONS AS REQUIRED. VERIFY ALL MOUNTING HEIGHTS AND TYPE OF CONNECTION PRIOR TO FINAL BIDS. REFER TO KITCHEN ELECTRICAL ROUGH-IN SCHEDULE FOR CIRCUITS, WIRE AND CONDUIT.
- C. FURNISH AND INSTALL ALL HOOD ELECTRICAL POWER AND CONTROL REQUIREMENTS. WIRING IN CONDUIT, AND ALL FINAL CONNECTIONS FOR COMPLETE SYSTEM, INCLUDING FINE SUPPRESSION. VERIFY WITH MANUFACTURER.
- D. FURNISH AND INSTALL ALL POWER AND CONTROL REQUIREMENTS INCLUDING ALL ET AND SF INTERLOCKING, CONTROLS, SWITCHES, RELAYS, ETC. MOUNT AND CONNECT ALL T-STATS. COORDINATE WITH MECHANICAL CONTRACTOR.
- E. NO EXTRA OR ALLOWANCES WILL BE ALLOWED THE ELECTRICAL CONTRACTOR FOR FAILURE TO PROPERLY COORDINATE ALL POWER AND CONTROL REQUIREMENTS OF ASSOCIATED SUB-CONTRACTORS. VERIFY PRIOR TO FINAL BIDS ALL GAO REQUIREMENTS.
- F. FURNISH AND INSTALL ALL DISCONNECTS, J-BOXES, POWER AND CONTROL WIRING IN CONDUIT AND ALL FINAL CONNECTIONS TO EQUIPMENT REMOTE ROOF-MOUNTED CONDENSER. VERIFY LOCATION.
- G. ALL COUNTERTOP RECEPTACLES SHALL BE MOUNTED HORIZONTALLY IN BACKSPASH. GENERAL CONVENIENCE RECEPTACLES SHALL BE MOUNTED VERTICALLY 15" TO CENTER LINE. ALL COVER PLATES ON STAINLESS OR DARK COLORED WALLS SHALL BE DARK BROWN COLORED. ALL KITCHEN EQUIPMENT COVERPLATES SHALL BE STAINLESS STEEL.
- H. ELECTRICAL CONTRACTOR SHALL PROVIDE AND INSTALL ALL ROUGH IN REQUIRED FOR SECURITY SYSTEM (BY OTHERS). ELECTRIC DOOR STRIKE TO BE CONTROLLED BY KEYS. MOMENTARY SWITCH AND WIRING TO EXIT ALARM AT RECEIVING DOOR. IF EXTERIOR GATE OR DOOR HAS AN UNAUTHORIZED OPENING, ALARM BELL AND PUSH BUTTON USED FOR STAIRWELL ACCESS SHALL BE USED AS MANUATOR FOR ALARM MODE. COORDINATE WITH ARCHITECT AND SECURITY SYSTEM INSTALLER.
- I. PROVIDE A 2" Ø ROUGH HOLE IN COUNTER FOR WIRING, TYPICAL EXCEPT AS SHOWN.

01 FLOOR PLAN - POWER  
SCALE: 1/4" = 1'-0"